

**Jacob Gemma**

**From:** Ione Varela [REDACTED]@AKT-UK.COM>  
**Sent:** 13 December 2018 18:32  
**To:** Anderson Scott  
**Cc:** Maguire Susanne; Nicholas Mitchell; Lucie Olivier; 3841 - South Kensington Station; Easton Fraser; Phiniefs Christopher; Enson Tu; [REDACTED]@native-land.com; Geary Rick; David Easton; Speer Michael; Gray Kate; Narita Anda  
**Subject:** 3841 - South Kensington station - Record information and design items  
**Attachments:** 11460\_SK\_0016.pdf; 3841-HS-SK-125 Record Information Request Sketch.pdf


Scott / All,

Further to our meeting yesterday, please find attached a sketch showing the main areas of development and the items that we are seeking available record information on. Due to the complexity of the site we view this as a live document that will feed into our Site Constraints drawing.

In terms of design, please clarify the following:

1. Accidental impact loads on all columns within the derailment zone on platforms are as stated in Figure 1 in TFL document S1053 (see extract below).

This is namely that the platform itself is designed by TFL to withstand a 500kN impact and provided the proposed building columns are suitably isolated as they thread through the platform they only need to withstand a design accidental load of 500kN at 3.0m above rail level in any direction non-concurrently. Please confirm that this understanding is correct.



2. In areas where rail-road vehicles can circulate (see attached RSH&P sketch 11460\_SK\_0016) – do columns need to be designed for errant road vehicle protection loading as per paragraph [3.2.16.9](#) in TFL document S1053?
3. We have agreed that design life of structures within the station needs to be 120years. In the proposed development along Pelham Street this will be applicable to the podium deck and its support (i.e. street level and below), however the building above deck level can be designed for a normal building design life (the exact location of the split is to be agreed). The 120 year design life will not be applicable to the new bullnose structure, please confirm.
4. [REDACTED]

We would be grateful if we could have confirmation / comments on the design items as well as estimated timeframes for the record searches.

Kind Regards,



**Ione Varela**  
Associate Director

**AKT II**  
Consulting Structural and Civil Engineers

White Collar Factory  
1 Old Street Yard  
London EC1Y 8AF

D  
T  
F  
M

[\[REDACTED\]@akt-uk.com](mailto: [REDACTED]@akt-uk.com)

[www.akt-uk.com](http://www.akt-uk.com)



Enabling award-winning  
architecture since 1996.

AKT II Limited

Registered in England and Wales number 07500271

Registered Office: White Collar Factory, 1 Old Street Yard, London EC1Y 8AF

Please consider the environment before printing this email.

This message contains confidential information and is intended only for the recipient. If you are not the recipient you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors or omissions in the contents of this message, which arise as a result of e-mail transmission. If verification is required please request a hard-copy version. By virtue of your responding to this email or emailing an employee of AKT II Limited, your name and contact information may be collected, retained, and/or processed by AKT II Limited, for its internal business purposes. Should you wish that this information not be collected, please contact the sender of this email. This communication is from AKT II Limited or one of its associated/subsidiary companies. This email and any attachments to it may be confidential and are intended solely for the use of the recipient/s. If you are not the intended recipient of this email, you must not take any action based upon its contents, nor copy or show it to anyone. Please contact the sender if you believe you have received this email in error and destroy it and any attachments immediately. It is your responsibility to protect your system from viruses and any other harmful code. We try to eliminate them from emails and attachments but we accept no liability for any which may remain.