



---

REPORT TITLE: **ERAD Sub-Frame Bush Testing**

CUSTOMER: **London EV Company Limited**  
**Li Close, Ansty Park, Coventry, CV7 9RF**

ORDER No: **71734**

ISSUE: **1**

REPORT No: **LEV0113**

DATE: **March 22**

AUTHOR: **[REDACTED]**

PAGE: **1 of 20**

---

Millbrook Proving Ground Limited. Registered Office Millbrook, Bedford, MK452JQ.  
Test Location: Aston Way, Leyland, PR26 7TZ  
T: +44 (0)1772 422911  
E: **[REDACTED]**@millbrook.co.uk  
Registered in England No. 02230262

Opinions and Interpretations expressed herein are outside the scope of UKAS Accreditation  
Items within this document marked with \*\* are not covered under the Millbrook ISO17025 accreditation





## Contents

1. TITLE .....	3
2. OBJECTIVES.....	3
3. CONCLUSIONS .....	3
4. TEST METHOD .....	3
5. RESULTS.....	6
6. DISCUSSION OF RESULTS .....	12
7. TEST EQUIPMENT .....	13
8. TEST PERIOD.....	13
APPENDIX A – SUBFRAME BUSH CRACK INSPECTION .....	14

No representation or warranty is given that tests performed under the terms of the Contract constitute, in themselves, a sufficient programme for the customer's purpose, nor that customer's equipment tested is suitable for a particular purpose. Certified that the specimens detailed hereon have been subjected to the tests as required by the contract/order unless otherwise stated. **Results contained within this report, only relate to the items tested**

	AUTHOR	CHECKED	AUTHORISED
SIGNATURE	[REDACTED]	[REDACTED]	[REDACTED]
NAME	[REDACTED]	[REDACTED]	[REDACTED]
JOB TITLE	Engineer	Principal Engineer	Manager
DATE	28/03/22	28/03/22	28/03/22

**1. Title**

1.1. ERAD Sub-Frame Bush Testing.

**2. Objectives**

2.1. Measure the stiffness of four e-rad mounts bushes on a used subframe.

2.2. Measure the stiffness of one e-rad mount bush on a new subframe.

**3. Conclusions**

3.1. The stiffness of the five mount bushes tested are shown in Table 1.

3.2. The stiffness values of all tested bushes were within the manufacturer specification for new bushes of:  $500 \pm 10\%$  N/mm.

**Table 1 - Bush Stiffness Summary**


Subframe Type	Bush Name	Stiffness (N/mm)
New	3B	519.5
Used	1A	462.6
Used	1B	505.5
Used	1C	501.2
Used	1D	516.4

**4. Test Method**

4.1. Testing required five bushes (four on a used subframe and one on a new subframe) to be subjected to a load input of approximately  $\pm 10$  kN at an input rate of 12 mm/min in order to obtain a corresponding stiffness value.


4.2. To apply this load a servo-hydraulic actuator, in displacement control was used to output a ramped input signal. The actuator was suspended directly above the sample as shown in Figure 1. The sample was clamped down to the bedplate to prevent any frame movement during the test. A load cell was used to return load feedback from the bush during the cycle.

**Figure 1 - Rig Setup**




- 4.3. The bushes were named with the convention shown in Figure 2. The used bush was labelled as subframe 1 and the new subframe was labelled as 3.

**Figure 2 - Bush Naming Convention**




- 4.4. The load was applied to the centre of the bush using a clevis and stepped shaft arrangement. This set up is shown in Figure 3 for A and B tests and Figure 4 for C and D.

**Figure 3 - A and B Bush Load Application**




**Figure 4 - C and D Bush Load Application**



## 5. Results

- 5.1. To obtain the stiffness of the bush, a gradient for the load vs displacement graph was needed. A section was taken from -3mm to 3mm for all bushes to obtain the stiffness value in the elastic region of the mount.
- 5.2. The new subframe was tested and produced the following Load vs Displacement graph in Figure 5. The load and displacement data beyond the bounds of the elastic region were then removed to produce the Load vs Displacement graph in Figure 6. A trendline was formed from the data and the gradient of this line was the stiffness of the bush.
- 5.3. This process was used for the bushes on subframe 1. The Load vs Displacement and truncated stiffness graphs for those bushes are shown in Figures 7-14 with a direct comparison to subframe 3.
- 5.4. Post-test, the subframe bushes were inspected for cracks in the rubber. The results of those bush inspections are available in Appendix A.

**Figure 5 - 3B (Load vs Displacement)**





**Figure 6 - 3B Filtered Data (Load vs Displacement, -3mm to 3mm)**




Figure 7 - 1A vs 3B (Load vs Displacement)




Figure 8 – 1A vs 3B (Load vs Displacement, -3mm to 3mm)






Figure 9 - 1B vs 3B (Load vs Displacement)




Figure 10 - 1B vs 3B (Load vs Displacement, -3mm to 3mm)




Figure 11 - 1C vs 3B (Load vs Displacement)




Figure 12 - 1C vs 3B (Load vs Displacement, -3mm to 3mm)




Figure 13 - 1D vs 3B (Load vs Displacement)





Figure 14 - 1D vs 3B (Load vs Displacement, -3mm to 3mm)



5.5. The stiffness of the tested bushes are shown in Table 2.

**Table 2 - Bush Stiffness**

Bush Name	Stiffness (N/mm)
3B	519.5
1A	462.6
1B	505.5
1C	501.2
1D	516.4

**6. Discussion of Results**

- 6.1. The stiffness of the 4 bushes on the used subframe and the bush on the new subframe were within the new production part stiffness specification of 500N/mm  $\pm$  10%. This criteria was specified by Boge, the bush manufacturer.
- 6.2. The older subframe bushes exhibited rubber cracks during post-test inspections. The same cracks were not visible on the new subframe bush.

## 7. Test Equipment

7.1. Test equipment shown in Table 3.

**Table 3 - Test Equipment Used**

Item	Stock Number	Calibration Due Date
Data Logger	MDS014	23/08/22
25kN Rated Schenck Load Cell	LDC048	07/09/22
25kN Schenck Actuator	TRD194	26/07/22
Zwick K7500 Controller	CON124	26/07/22

## 8. Test Period

**Table 4 - Key Phases**

Key Phases	Date
Parts Arrival	02/03/22
Rig Design Approval	15/03/22
Test Start	16/03/22
Test Completion	17/03/22

Report No. LEV0113  
Issue No. 1



Page 14 of 20

## **Appendix A – Subframe Bush Crack Inspection**



**Figure 15 – 1A Bush Investigation**



**Figure 16 – 1A Bush Investigation**



**Figure 17 – 1B Bush Investigation**




**Figure 18 – 1B Bush Investigation**





**Figure 19 – 1C Bush Investigation**



**Figure 20 – 1C Bush Investigation**



**Figure 21 – 1D Bush Investigation**



**Figure 22 - 1D Bush Investigation**






**Figure 23 - 3B Bush Investigation**



**Figure 24 - 3B Bush Investigation**



Report No. LEV0113  
Issue No. 1



Page 20 of 20

----- END OF TEST REPORT -----

**Customer Satisfaction**

In order to ensure that the service that we provide is of the standard required by our customers, we welcome any feedback on the testing or calibration services provided.

Should you wish to make any comments or provide feedback and improvements, please do not hesitate to contact the Operations Director, [REDACTED] ([REDACTED]@[REDACTED].com) or your sales contact.

Your answers will be treated in the strictest confidence.

----- END OF REPORT -----