



Scientific Services
for Transport & Industry

4-RAIL
Services Ltd

Client : Mr. Paul Hewitt
London Underground
HMU
4th Floor, 15 Westferry Circus
Canary Wharf
London, E14 4HD

Head Office: Unit 3, Metro Centre,
Britannia Way, London, NW10 7PA
Phone: 020 8955 9680 Fax: 020 8955 9689

Laboratory: Unit 11, Ironbridge Close,
Great Central Way, London, NW10 0UF
Phone: 020 8955 1700 Fax: 020 8830 1003
Email: enquiries@4-rail.com
Web: www.4-rail.com

Results of Asbestos Identification Finchley Central ES7104c

Report no: 4RS-JP-163207-R559176
Client's reference number(s): ES7104c
4-RAIL Services (4RS) reference number(s): 163207/251016/01
Date sample(s) received: 26th October 2016
Date(s) of examination(s): 31st October 2016
Issue date: 4th November 2016

Test Method

Samples were examined in accordance with the methods described in the HSE Document *HSG 248 Asbestos: The analysts' guide for sampling, analysis and clearance procedures* and in-house test procedure 4R-E220. The results relate only to the items submitted for testing. Where samples have been taken by others, 4-RAIL Services do not accept any responsibility for the sampling.

4RS Sample No	Sample Description*	Asbestos Type(s) Detected
163207/251016/01	Asbestos Insulation Board (AIB) panels and debris, 10m ² , to switch kiosk 10m off Finchley Central Platform 1 towards East Finchley behind cable run on Northbound track cess.	Amosite

*The sample description is outside the scope of UKAS accreditation.

Samples examined will be retained by 4-RAIL Services for a period of 6 months, unless otherwise specified by the Client.

Analysed by: [REDACTED], Laboratory Manager

Prepared by: [REDACTED], Delivery Support Administrator

Certified by: [REDACTED], Consultant

Additional comments

The opinions and interpretations expressed herein are outside the scope of the UKAS Accreditation

4-RAIL Services Limited were requested by Mr. Paul Hewitt, London Underground, HMU, to attend site to undertake sampling of materials suspected to contain asbestos from Finchley Central ES7104c.

Sampling was undertaken during engineering hours on 25th/26th October 2016 by Mr. V. Chauhan of 4-RAIL Services Ltd.

One sample was taken for analysis and it was found to contain asbestos.

Figure 1 below shows Asbestos Insulation Board (AIB) panels and debris, 10m², to switch kiosk 10m off Finchley Central Platform 1 towards East Finchley behind cable run on Northbound track cess.

The sample was found to contain Amosite asbestos.

Sample Ref. 163207/251016/01



CONDITIONS OF ISSUE OF REPORTS.

THIS REPORT IS ISSUED TO THE CLIENT IN CONFIDENCE AND SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF 4-RAIL SERVICES.

QUERIES OR FURTHER INFORMATION.

ANY QUERIES OR REQUESTS FOR ADDITIONAL INFORMATION ON THE SUBJECT OF THIS REPORT SHOULD BE ADDRESSED TO THE AUTHOR WHO MAY BE CONTACTED AT THE ADDRESS GIVEN ON THE TITLE PAGE.